



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

April 03, 2024

Kelly Moore
Seymour R-II School District
416 E. Clinton
Seymour, MO 65746

RE: High School

Dear Kelly Moore:

Please find enclosed the analytical results for the **44** sample(s) the laboratory received on **3/20/24 2:40 pm** and logged in under work order **HC03206**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise . We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

A handwritten signature in black ink, appearing to read "Chenise Lambert-Sykes".

Chenise Lambert-Sykes
Project Manager
(314)432-0550
Chenise.Lambert-Sykes@pacelabs.com



SAMPLE RECEIPT CHECK LIST

Items not applicable will be marked as in compliance

Work Order HC03206

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
YES	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
NO	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
NO	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided



ANALYTICAL RESULTS

Sample: HC03206-01
Name: GH 05760-30 1
Matrix: Drinking Water - Grab

Sampled: 03/11/24 08:25
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method

Total Metals - PIA

Table row for Lead: Result 5.66, Unit ug/L, Prepared 03/25/24 11:31, Dilution 1, MRL 1.00, Analyzed 03/25/24 15:44, Analyst BRS, Method EPA 200.8 REV 5.4

Sample: HC03206-02
Name: GH 05760-30 2
Matrix: Drinking Water - Grab

Sampled: 03/11/24 08:25
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method

Total Metals - PIA

Table row for Lead: Result 5.95, Unit ug/L, Prepared 03/25/24 11:31, Dilution 1, MRL 1.00, Analyzed 03/25/24 15:49, Analyst BRS, Method EPA 200.8 REV 5.4

Sample: HC03206-03
Name: GH 05760-33 1
Matrix: Drinking Water - Grab

Sampled: 03/11/24 08:29
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method

Total Metals - PIA

Table row for Lead: Result 6.55, Unit ug/L, Prepared 03/25/24 11:31, Dilution 1, MRL 1.00, Analyzed 03/25/24 15:50, Analyst BRS, Method EPA 200.8 REV 5.4

Sample: HC03206-04
Name: GH 05760-33 2
Matrix: Drinking Water - Grab

Sampled: 03/11/24 08:29
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method

Total Metals - PIA

Table row for Lead: Result 6.50, Unit ug/L, Prepared 03/25/24 11:31, Dilution 1, MRL 1.00, Analyzed 03/25/24 15:51, Analyst BRS, Method EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: HC03206-05
Name: GH 05760-34 1
Matrix: Drinking Water - Grab

Sampled: 03/11/24 08:32
Received: 03/20/24 14:40
PO #: Maintenance

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	6.73	ug/L		03/25/24 11:31	1	1.00	03/25/24 15:53	BRS	EPA 200.8 REV 5.4

Sample: HC03206-06
Name: GH 05760-34 2
Matrix: Drinking Water - Grab

Sampled: 03/11/24 08:32
Received: 03/20/24 14:40
PO #: Maintenance

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	6.56	ug/L		03/25/24 11:31	1	1.00	03/25/24 15:57	BRS	EPA 200.8 REV 5.4

Sample: HC03206-07
Name: GH 05760-37 1
Matrix: Drinking Water - Grab

Sampled: 03/11/24 08:40
Received: 03/20/24 14:40
PO #: Maintenance

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	6.66	ug/L		03/25/24 11:31	1	1.00	03/25/24 15:58	BRS	EPA 200.8 REV 5.4

Sample: HC03206-08
Name: GH 05760-37 2
Matrix: Drinking Water - Grab

Sampled: 03/11/24 08:40
Received: 03/20/24 14:40
PO #: Maintenance

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	6.62	ug/L		03/25/24 11:31	1	1.00	03/25/24 16:00	BRS	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: HC03206-09
Name: GH 05760-38 1
Matrix: Drinking Water - Grab

Sampled: 03/11/24 08:44
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 3.72, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:01, BRS, EPA 200.8 REV 5.4

Sample: HC03206-10
Name: GH 05760-38 2
Matrix: Drinking Water - Grab

Sampled: 03/11/24 08:44
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 4.88, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:02, BRS, EPA 200.8 REV 5.4

Sample: HC03206-11
Name: GH 05760-43 1
Matrix: Drinking Water - Grab

Sampled: 03/11/24 08:48
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 5.32, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:04, BRS, EPA 200.8 REV 5.4

Sample: HC03206-12
Name: GH 05760-43 2
Matrix: Drinking Water - Grab

Sampled: 03/11/24 08:48
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 6.77, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:08, BRS, EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: HC03206-13
Name: GH 05760-44 1
Matrix: Drinking Water - Grab

Sampled: 03/11/24 08:52
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 3.35, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:09, BRS, EPA 200.8 REV 5.4

Sample: HC03206-14
Name: GH 05760-44 2
Matrix: Drinking Water - Grab

Sampled: 03/11/24 08:52
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 2.41, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:14, BRS, EPA 200.8 REV 5.4

Sample: HC03206-15
Name: GH 05760-46 1
Matrix: Drinking Water - Grab

Sampled: 03/11/24 08:55
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 2.10, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:15, BRS, EPA 200.8 REV 5.4

Sample: HC03206-16
Name: GH 05760-46 2
Matrix: Drinking Water - Grab

Sampled: 03/11/24 08:55
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 2.66, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:16, BRS, EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: HC03206-17
Name: GH 05760-47 1
Matrix: Drinking Water - Grab

Sampled: 03/11/24 08:59
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 2.25, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:18, BRS, EPA 200.8 REV 5.4

Sample: HC03206-18
Name: GH 05760-47 2
Matrix: Drinking Water - Grab

Sampled: 03/11/24 08:59
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 2.06, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:19, BRS, EPA 200.8 REV 5.4

Sample: HC03206-19
Name: GH 05760-48 1
Matrix: Drinking Water - Grab

Sampled: 03/11/24 09:03
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 2.77, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:21, BRS, EPA 200.8 REV 5.4

Sample: HC03206-20
Name: GH 05760-48 2
Matrix: Drinking Water - Grab

Sampled: 03/11/24 09:03
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 2.89, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:22, BRS, EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: HC03206-21
Name: GH 05760-51 1
Matrix: Drinking Water - Grab

Sampled: 03/11/24 09:10
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 3.30, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:24, BRS, EPA 200.8 REV 5.4

Sample: HC03206-22
Name: GH 05760-51 2
Matrix: Drinking Water - Grab

Sampled: 03/11/24 09:10
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 3.25, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:31, BRS, EPA 200.8 REV 5.4

Sample: HC03206-23
Name: GH 05760-52 1
Matrix: Drinking Water - Grab

Sampled: 03/11/24 09:14
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 2.81, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:32, BRS, EPA 200.8 REV 5.4

Sample: HC03206-24
Name: GH 05760-52 2
Matrix: Drinking Water - Grab

Sampled: 03/11/24 09:14
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 3.09, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:34, BRS, EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: HC03206-25
Name: GH 05760-53 1
Matrix: Drinking Water - Grab

Sampled: 03/11/24 09:17
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 3.40, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:35, BRS, EPA 200.8 REV 5.4

Sample: HC03206-26
Name: GH 05760-53 2
Matrix: Drinking Water - Grab

Sampled: 03/11/24 09:17
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 3.75, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:36, BRS, EPA 200.8 REV 5.4

Sample: HC03206-27
Name: GH 05760-54 1
Matrix: Drinking Water - Grab

Sampled: 03/11/24 09:20
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 3.70, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:38, BRS, EPA 200.8 REV 5.4

Sample: HC03206-28
Name: GH 05760-54 2
Matrix: Drinking Water - Grab

Sampled: 03/11/24 09:20
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 3.80, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:39, BRS, EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: HC03206-29
Name: GH 05760-55 1
Matrix: Drinking Water - Grab

Sampled: 03/11/24 09:24
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 3.71, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:41, BRS, EPA 200.8 REV 5.4

Sample: HC03206-30
Name: GH 05760-55 2
Matrix: Drinking Water - Grab

Sampled: 03/11/24 09:24
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 3.54, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:42, BRS, EPA 200.8 REV 5.4

Sample: HC03206-31
Name: GH 05760-56 1
Matrix: Drinking Water - Grab

Sampled: 03/11/24 09:40
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 3.03, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:44, BRS, EPA 200.8 REV 5.4

Sample: HC03206-32
Name: GH 05760-56 2
Matrix: Drinking Water - Grab

Sampled: 03/11/24 09:40
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 3.84, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:51, BRS, EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: HC03206-33
Name: GH 05760-57 1
Matrix: Drinking Water - Grab

Sampled: 03/11/24 09:45
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 3.63, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:52, BRS, EPA 200.8 REV 5.4

Sample: HC03206-34
Name: GH 05760-57 2
Matrix: Drinking Water - Grab

Sampled: 03/11/24 09:45
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 3.71, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:54, BRS, EPA 200.8 REV 5.4

Sample: HC03206-35
Name: GH 05760-58 1
Matrix: Drinking Water - Grab

Sampled: 03/11/24 09:48
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 3.63, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:55, BRS, EPA 200.8 REV 5.4

Sample: HC03206-36
Name: GH 05760-58 2
Matrix: Drinking Water - Grab

Sampled: 03/11/24 09:48
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 3.52, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:56, BRS, EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: HC03206-37
Name: GH 05760-61 1
Matrix: Drinking Water - Grab

Sampled: 03/11/24 09:52
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 3.91, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:58, BRS, EPA 200.8 REV 5.4

Sample: HC03206-38
Name: GH 05760-61 2
Matrix: Drinking Water - Grab

Sampled: 03/11/24 09:52
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 3.85, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 16:59, BRS, EPA 200.8 REV 5.4

Sample: HC03206-39
Name: GH 05760-62 1
Matrix: Drinking Water - Grab

Sampled: 03/11/24 09:56
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 3.70, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 17:01, BRS, EPA 200.8 REV 5.4

Sample: HC03206-40
Name: GH 05760-62 2
Matrix: Drinking Water - Grab

Sampled: 03/11/24 09:56
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 3.75, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 17:05, BRS, EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: HC03206-41
Name: GH 05760-63 1
Matrix: Drinking Water - Grab

Sampled: 03/11/24 10:06
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 3.73, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 17:06, BRS, EPA 200.8 REV 5.4

Sample: HC03206-42
Name: GH 05760-63 2
Matrix: Drinking Water - Grab

Sampled: 03/11/24 10:06
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 3.59, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 17:11, BRS, EPA 200.8 REV 5.4

Sample: HC03206-43
Name: GH 05760-64 1
Matrix: Drinking Water - Grab

Sampled: 03/11/24 10:10
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 3.73, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 17:12, BRS, EPA 200.8 REV 5.4

Sample: HC03206-44
Name: GH 05760-64 2
Matrix: Drinking Water - Grab

Sampled: 03/11/24 10:10
Received: 03/20/24 14:40
PO #: Maintenance

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 3.69, ug/L, 03/25/24 11:31, 1, 1.00, 03/25/24 17:14, BRS, EPA 200.8 REV 5.4



NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050



Certified by: Chenise Lambert-Sykes, Project Manager

LAB USE ONLY. APTS: WorkOrder, Login, Label Here
HCO3206
3206 9/2
HCO3206
SAB



Scan QR Code for instructions

Specify Container Size**
Identify Container Preservation Type**
Analysis Requested

Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 50mL, (7) 25mL, (8) 10mL, (9) 5mL, (10) 1mL, (11) Other
Preservative Type: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NH4SO4, (8) Soda, (9) Phosphate, (10) Ascorbic Acid, (11) Other
Proj. Mgr.
AcctNum./Client ID:
Table #:
Profile / Template:
Prelog / Sortie Ord. ID:
Sample Comment:
Preservation or container identifier for sample

Turb Check
Drinking Water Lead (Pb)

Customer Project #
Project Name:
Drinking Water Lead
Site Collection Info/Facility ID (as applicable):
High School

Company Name: Pace
Street Address:
416 E. Clinton
Seymour, MO 65746

Contact/Report To: Kelly Moore
Phone #: 417-741-0238
E-Mail: kmoore@seymourschool.net
Cc E-Mail:
Invoice #:
Purchase Order # (if applicable):
Quota #: 00143659
County / Size origin of sample(s):

Company Name: Pace
Street Address:
416 E. Clinton
Seymour, MO 65746

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Matrix #	Comp / Grab	Customer Sample ID	Composite Start Date	Time	Collected or Composite End Date	Time	# Cont.	Residual Chlorine Result	Units
DW	X	GH 05760 - 30	3-11-24	8:25	3-11-24	8:30			
DW	X	GH 05760 - 30	3-11-24	8:39	3-11-24	8:40			
DW	X	GH 05760 - 33	3-11-24	8:39	3-11-24	8:40			
DW	X	GH 05760 - 34	3-11-24	8:39	3-11-24	8:40			
DW	X	GH 05760 - 37	3-11-24	8:40	3-11-24	8:40			
DW	X	GH 05760 - 38	3-11-24	8:44	3-11-24	8:44			
DW	X	GH 05760 - 38	3-11-24	8:44	3-11-24	8:44			

Additional Instructions from Pace*:
Collected By: Ruben Beyers
Printed Name: Ruben Beyers
Signature: [Signature]

Customer Remarks / Special Conditions / Possible Hazards:
Trading Number: 3206 24 1010
Date/Time: 3-20-24 1010
Delivered by: [] In-Person [X] Courier
Date/Time: [] FedEx [] UPS [] Other

Customer Remarks / Special Conditions / Possible Hazards:
Trading Number: 3206 24 1446
Date/Time: 3-20-24 1446
Delivered by: [] In-Person [X] Courier
Date/Time: [] FedEx [] UPS [] Other

Customer Remarks / Special Conditions / Possible Hazards:
Trading Number: 3206 24 1446
Date/Time: 3-20-24 1446
Delivered by: [] In-Person [X] Courier
Date/Time: [] FedEx [] UPS [] Other

Customer Remarks / Special Conditions / Possible Hazards:
Trading Number: 3206 24 1446
Date/Time: 3-20-24 1446
Delivered by: [] In-Person [X] Courier
Date/Time: [] FedEx [] UPS [] Other

Customer Remarks / Special Conditions / Possible Hazards:
Trading Number: 3206 24 1446
Date/Time: 3-20-24 1446
Delivered by: [] In-Person [X] Courier
Date/Time: [] FedEx [] UPS [] Other

Customer Remarks / Special Conditions / Possible Hazards:
Trading Number: 3206 24 1446
Date/Time: 3-20-24 1446
Delivered by: [] In-Person [X] Courier
Date/Time: [] FedEx [] UPS [] Other


Customer Remarks / Special Conditions / Possible Hazards:
Trading Number: 3206 24 1446
Date/Time: 3-20-24 1446
Delivered by: [] In-Person [X] Courier
Date/Time: [] FedEx [] UPS [] Other

Customer Remarks / Special Conditions / Possible Hazards:
Trading Number: 3206 24 1446
Date/Time: 3-20-24 1446
Delivered by: [] In-Person [X] Courier
Date/Time: [] FedEx [] UPS [] Other

Pace® Location Requested (City/State):
 Pace® School District
 416 E. Clinton
 Seymour, MO 65746

Chain-of-Custody Analytical Request Document
 Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

LAB USE ONLY - Affix Workorder/LogIn Label Here
 HCD3206
 HCD3204
 SFB



Scan QR Code for instructions

Company Name: Seymour R-II School District
 Street Address:
 416 E. Clinton
 Seymour, MO 65746

Customer Project #:
 Project Name:
 Drinking Water Lead

Site Collection Info/Facility ID (as applicable):
 Hight School

Time Zone Collected: [] AK [] PT [] MT [] ET
 Data Deliverables:
 [] Level II [] Level III [] Level IV
 [] EQUIS
 [] Other:

Regulatory Program (DW, RCRA, etc.) as applicable:
 Rush (Pre-approval required):
 [] Same Day [] 1 Day [] 2 Day [] 3 Day Other

Reportable [] Yes [] No
 DW PWSID # or WW Permit # as applicable:
 Analysis:
 Field Filtered (if applicable): [] Yes [] No

Customer Name:
 Kelly Moore
 Phone #: 417-741-0238
 E-Mail: kmoore@seymourschool.net
 Cc E-Mail:
 Invoice to:
 Invoice E-mail:
 Purchase Order # (if applicable):
 Quote #: 00143659
 County / Size origin of sample(s):

Specify Container Size **
 Identify Container Preservation Type **
 Analysis Requested

Label Use Only
 Proj. Mgr:
 AcctNum / Client ID:
 Table #:
 Profile / Template:
 Priority / Bottle Ord. ID:
 Preservation no. or container identifier

Drinking Water Lead (Pb)
 Turb Check

Matrix *	Comp / Grab	Composite Start		# Cont.	Residual Chlorine Result Units
		Date	Time		
DW 05760-43	X	3-11-24	8:48		
DW 05760-43	X	3-11-24	+30		
DW 05760-44	X	3-11-24	8:52		
DW 05760-44	X	3-11-24	+30		
DW 05760-46	X	3-11-24	8:55		
DW 05760-46	X	3-11-24	+30		
DW 05760-47	X	3-11-24	8:59		
DW 05760-47	X	3-11-24	+30		
DW 05760-48	X	3-11-24	9:03		
DW 05760-48	X	3-11-24	+30		

Customer Remarks / Special Conditions / Possible Hazards:
 Collected By: *Robyn Bessie*
 Printed Name: *Robyn Bessie*
 Signature: *Robyn Bessie*

Additional Instructions from Page 1:
 Required by Company (Signature):
 Received by Company (Signature):
 Date/Time: 3-20-24

Required by Company (Signature):
 Received by Company (Signature):
 Date/Time: 3-20-24

Required by Company (Signature):
 Received by Company (Signature):
 Date/Time: 3-20-24

Required by Company (Signature):
 Received by Company (Signature):
 Date/Time: 3-20-24

Required by Company (Signature):
 Received by Company (Signature):
 Date/Time: 3-20-24

Required by Company (Signature):
 Received by Company (Signature):
 Date/Time: 3-20-24

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at <http://www.pacehills.com/pace-hills-conditions/>

Thermometer ID: _____ Obs. Temp. (C): _____
 Corrosive Factor (C): _____
 Tracking Number: _____
 Delivered by: [] In-Person [X] Courier
 [] FedEx [] UPS [] Other

Date/Time: 3-20-24 10:40
 Date/Time: 3-20-24 10:40
 Date/Time: 3-20-24 10:40
 Date/Time: 3-20-24 10:40

Page: 320124 1400 of _____

ENV-FRM-CORQ-0019_V02_11.01.23 ©

LAB USE ONLY - Affix Workorder/LogIn Label Here
 3206 NS
 HC03204
 SAB



Scan QR Code for instructions

Specify Container Size **
 Identify Container Preservation Type ***
 Analysis Requested

Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 50mL, (7) 25mL, (8) 10mL, (9) 5mL, (10) Other
 Preservation Types: (1) None, (2) H2SO4, (3) HClO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NH4OH, (8) HNO3, (9) Ascorbic Acid, (10) MethOH, (11) Other

Proj. Mgr:
 AccNum / Client ID:
 Table #:
 Profile / Template:
 Prelog / Bottle Ord. ID:
 Sample Comment

Preservation (in compliance identified for sample)

Customer Remarks / Special Conditions / Possible Hazards:

Coolers Thermometer ID: Correction Factor (°C) Out Temp (°C) Correction Term (°C) () On log N

Trading Number:
 Date/Time: 3-20-24 10:40
 Delivered by: () In-Person () Courier
 Date/Time:
 Date/Time:
 Date/Time:
 Page: of
 ENVY-FRM-CORQ-0019_V02_11-01-23 ©

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Project Name:
 Drinking Water Lead
 Site Collection Info/Facility ID (as applicable):
 High School

City/State of sample(s):
 Reportable () Yes () No
 DW PWSID # or WW Permit # as applicable:
 Field Filtered (if applicable): () Yes () No
 Analysts:

Time Zone Collected: [] AK [] PT [] MT [] CT [] ET
 Regulatory Program: (DW, RCRA, etc.) as applicable:
 Rush (Pre-approval required):
 [] Same Day [] 1 Day [] 2 Day [] 3 Day Other _____
 Date Requested:
 [] Other _____

Matrix *
 Comp / Grab
 Date
 Time
 Composite Start
 Collected or Composite End
 Date
 Time
 # Cont.
 Residual Chlorine
 Result
 Units

Customer Sample ID	Matrix *	Comp / Grab	Date	Time	Composite Start	Collected or Composite End	Date	Time	# Cont.	Residual Chlorine	Result	Units
GH 05760-51	DW X	X	3-11-24	9:10								
GH 05760-51	DW X	X	3-11-24	+30								
GH 05760-52	DW X	X	3-11-24	9:14								
GH 05760-52	DW X	X	3-11-24	+30								
GH 05760-53	DW X	X	3-11-24	9:17								
GH 05760-53	DW X	X	3-11-24	+30								
GH 05760-54	DW X	X	3-11-24	9:20								
GH 05760-54	DW X	X	3-11-24	+30								
GH 05760-55	DW X	X	3-11-24	9:24								
GH 05760-55	DW X	X	3-11-24	+30								

Additional Instructions from Page 2:
 Collected By: Ruben Beron
 Printed Name: Ruben Beron
 Signature: [Signature]


Date/Time:
 Date/Time:
 Date/Time:
 Date/Time:

Received by/Company: [Signature]
 Received by/Company: [Signature]
 Received by/Company: [Signature]
 Received by/Company: [Signature]

Submitting a sample via the chain of custody constitutes acknowledgment and acceptance of the State of Missouri's Terms and Conditions found at <https://www.mdcslabs.com/resources/chain-of-custody>

LAB USE ONLY - After WorkOrder Login Label Here
 HCO3206
 3206
 SAB

Scan QR Code for instructions



Specify Container Size **
 Identify Container Preservation Type ***
 Analysis Requested

Lab Use Only
 PreservBin no n-contaminant identified
 Sample Comment

Customer Name: Pace
 Street Address: 416 E. Clinton
 Seymour, MO 65746

Project Name: Drinking Water Lead
 Site Collection Info/Facility ID (as applicable):
 Time Zone Collected: [] AK [] PT [] MT [] CT [] ET

Regulatory Program: (DW, RCRA, etc.) as applicable:
 Reportable [] Yes [] No
 DW PWSID # or WW Permit # as applicable:
 Field Filtered (if applicable): [] Yes [] No

Analysis:
 Date Requested:
 * Matrix Codes (insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Soil/Solid (SS), Oil (O), Wipe (WP), Tissue (T), Surface Water (SW), Sediment (SD), Sludge (SL), Caulk (C), Leachate (L), Biosolid (BS), Other (OT)

Customer Project #: 00143659
 County/State origin of sample(s):
 Purchased Order # (if applicable):
 Invoice to:
 Invoice E-mail:
 Contact/Report To: Kelly Moore
 Phone #: 417-741-0238
 E-Mail: kmoore@seymourschool.net
 Cc E-Mail:

Matrix #	Customer Sample ID	Comp / Grab	Composite Start Date	Time	Collected or Composite End Date	Time	# Cont.	Residual Chlorine Result	Units
G1H	05760-56	DW X	3-11-24	9:40					
G1N	05760-56	DW X	3-11-24	7:30					
G1B	05760-57	DW X	3-11-24	9:45					
G1H	05760-57	DW X	3-11-24	7:30					
G1H	05760-58	DW X	3-11-24	9:48					
G1H	05760-61	DW X	3-11-24	7:30					
G1H	05760-61	DW X	3-11-24	7:30					
G1H	05760-62	DW X	3-11-24	9:56					
G1H	05760-62	DW X	3-11-24	7:3					

Additional Instructions from Pace:
 Collected By: Kelly Moore
 Printed Name: Kelly Moore
 Signature: Kelly Moore

Received by/Company Signature: Kelly Moore
 Date/Time: 3-20-24 10:40
 Received by/Company Signature: Kelly Moore
 Date/Time: 3-20-24 10:40

Received by/Company Signature: Kelly Moore
 Date/Time: 3-20-24 10:40
 Received by/Company Signature: Kelly Moore
 Date/Time: 3-20-24 10:40

Received by/Company Signature: Kelly Moore
 Date/Time: 3-20-24 10:40
 Received by/Company Signature: Kelly Moore
 Date/Time: 3-20-24 10:40

Received by/Company Signature: Kelly Moore
 Date/Time: 3-20-24 10:40
 Received by/Company Signature: Kelly Moore
 Date/Time: 3-20-24 10:40

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at <https://www.pace-labs.com/resources/pace-terms-and-conditions>
 Page: 1 of 1
 ENV-FRM-CORQ-0013_V02_11.01.23

LAB USE ONLY - Arix Workorder Login Label Here
 HC03206



Scan QR Code for instructions

CHAIN-OF-CUSTODY Analytical Request Document
Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Pace® Location Requested (City/State):
 Pace, Missouri, MO
 944 Anglin Rd.
 Hazelwood, MO 63042

Company Name: Seymour R-II School District
Street Address: 416 E. Clinton
 Seymour, MO 65746
Customer Project #:
Project Name: Drinking Water Lead
Site Collection #s/Facility ID (as applicable):
 High school 1

Contact/Report To: Kelly Moore
Phone #: 417-741-0238
E-Mail: kmoore@seymourschool.net
Cc E-Mail:
Invoice to:
Invoice E-mail:
Purchase Order # (if applicable):
Quote #: 00143659
County/State of sample(s):

Time Zone Collected: [] AK [] PT [] MT [] ET [] CT
Data Deliverables:
 [] Level I [] Level III [] Level IV
 [] EQUIS
 [] Other

Regulatory Program: (DW, RCRA, etc.) as applicable: _____
Rush (Pre-approval required):
 [] Same Day [] 1 Day [] 2 Day [] 3 Day Other _____
Date Results Requested:
 DW PWSID # or WW Permit # as applicable: _____
Analysis:
 Field Filtered (if applicable): [] Yes [] No
 Turb Check

Specify Container Size **
 (1) 23mL, (2) 100mL, (3) 400mL, (4) 1L, (5) 2L, (6) 4L, (7) 10L, (8) 20L, (9) 50L, (10) 100L, (11) 200L, (12) 500L, (13) 1000L
Identify Container Preservative Type**
 *** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) an Aldehyde, (7) Nitrocell, (8) SO2, (9) Thiosulfate, (10) Acetic Acid, (11) HNO3, (12) Other
Analysis Requested

Customer Sample ID
 GN 05760-63
 GN 05760-63
 GN 05760-64
 GN 05760-64

Proj. Mgr:
Account / Client ID:
Table #:
Profile / Template:
Preserv / Bottle Ord. ID:
Sample Comment

Customer Sample ID	Matrix *	Comp / Grab	Composite Start		# Cont.	Residual Chlorine
			Date	Time		
GN 05760-63	DW	X	3-11-24	10:06		
GN 05760-63	DW	X	3-11-24	1:30		
GN 05760-64	DW	X	3-11-24	10:10		
GN 05760-64	DW	X	3-11-24	1:30		

Drinking Water Lead (Pb)

Additional Instructions from Pace®:
 Collected By: Ruth Berc
 Printed Name: Ruth Berc
 Signature: Ruth Berc

Customer Remarks / Special Conditions / Possible Hazards:

Received by (Company, Signature):
 Received by (Company, Signature):
 Received by (Company, Signature):
 Received by (Company, Signature):

Temperature ID: _____ **Obs. Temp. (°C):** _____ **Corrected Temp. (°C):** _____

Date/Time: 3-20-24 10:40
Date/Time:
Date/Time:
Date/Time:

Tracking Number:

Delivered by: [] In-Person [] Courier [] FedEx [] UPS [] Other

Page: _____ **of** _____

EW-PRM-CORQ-0019_V02_11-01-23